



WATCO, INC.
PHONE – (800)315-5333 EMAIL – info@southwesternutility.com
PO BOX 85160 TUCSON, AZ 85754

April 5, 2014

ORIGINAL

RE: Watco, Inc. – Canyon Vista System: Docket No. W-20475A-12-0143 Decision No. 73730

To Whom It May Concern:

In accordance with the aforementioned Decision Number, attached hereto is a 12-month water use data report.

Since the water loss reported is in excess of 10%, Watco, Inc. has enacted the following to reduce the water loss reported in the Canyon Vista System.

Summary: The Canyon Vista System contains a recently installed well, tank, booster system, transmission/distribution system and appurtenances. The System was subject to, and satisfactorily passed, all applicable testing for new systems. Therefore, the possibility of water loss being attributed to a leak is not feasible.

- 1) The storage tank installed in the Canyon Vista System contains excess capacity for the number of customers and gallons sold. The excess capacity can create a situation where gallons sold will exceed gallons pumped. Meter reads and associated usage will be reviewed on a monthly basis for accuracy and reasonableness.
- 2) The installation of the well master meter will be reviewed to ensure the accuracy of the meter reading; the possibility exists that an incorrectly installed meter will register inaccurately. Manufacturer's specifications and installation instructions will be reviewed to ensure accurate installation. If the review indicates that an adjustment is needed, a feasibility assessment will be performed and a subsequent recommendation developed.
- 3) Non-metered water usage identified during the month will be calculated and recorded so additional explanations pertaining to water loss can be retained.

Thank you. Have an excellent day!

Best Regards,

Thomas Grapp

Arizona Corporation Commission

DOCKETED

APR 09 2014

DOCKETED BY

RECEIVED
2014 APR -9 1 A 10:52
ARIZONA CORPORATION COMMISSION
DOCKET CONTROL

Watco, Inc. - Canyon Vista System (PWS 09-091)
Docket No. W-20475A-12-0143 Decision No. 73730

	Number of Customers	Gallons Pumped (Thousands)	Gallons Sold (Thousands)
January	5	30	18
February	5	-4	55
March	6	144	12
April	5	20	15
May	5	31	38
June	5	58	55
July	5	62	63
August	5	49	45
September	5	36	38
October	5	37	36
November	5	36	27
December	5	0	11
TOTAL		499	413
Water Loss	17%		